

SUPPLY LIGHTING AND CABLE

<u>UNIT</u>	<u>QTY</u>		NO.	
		1-SUPPLY OF SINGLE ARM LIGHTING COLUMN, 8-METER HIGHT MADE OF GALVANIZED STEEL, PROVIDED WITH 10 AMPS SWITCH, SUTABLE FOR CABLE TREATMENT ATTACHMENT, and ARM EXTENTION TO BE 1.5 m.	971	
		2-DO.BUT 10m HIGHT.	30	
		3-DO.BUT 12m HIGHT.	320	
		4- SUPPLY OF MERCURY VAPOUR LIGHTING LANTERN 220V, 50 HZ, 250 W COMPLETE WITH LAMPS AND CONTROLS.	971	
		5- SUPPLY OF MERCURY VAPOR LIGHTING LANTERN 220V ,50 HZ ,250 W COMPLETE WITH LAMPS AND CONTROLS.	190	
		6-DO,BUT 400W.	320	
		7- SUPPLY OF CABLES (4X 16 mm ²) CROSS-SECTION PINEAR METER P.V.C INSULATED MADE OF COPPER IN ACCORODANCE WITH V.D.E SPECIFICATIONS COMPLETE WITH CALBE TERMINALS.	36400	
		8- SUPPLY OF UNINSULATED STRANDED COPPER WIRE SIZE (1X16 mm ²) WITH CABLE PINEAR METER TERMINAL.	63400	
		9- SUPPLY AND LAYING OF LOW-TENSION PINEAR METER ELECTRIC CABLE 0.61 KV. SIZE {3X5mm ² +50mm ² } CONDUCTOR TO BE OF COPPER INSULATED BY P.V.C ARMoured WITH GALVANIZED WIRE TOTALLY SHEATHED WITH P.V.C INCLUDING CABLE TERMINALS.	220	
		10-DO.BUT SIZE {3X70mm ² -35mm ² }LINER METER.	690	
		11-DO.BUT SIZE {3X120mm ² +35mm ² }LINEAR METER .	560	
		12-SUPPLY OF CONTROLE BOARED 380/220V, 3PHASE, 4WIRES, 50HZ MADE OF GALVANIZE STEEL WITH GRAY PAINT RESISTANT TO CLIMATIC CONDITIONS OF THICKNISS 2mm COMPLETE WITH BUS-BARS, CONTACTORS , CIRCUIT BREAKERS TIMERS , AND ALL NECESSNRY INSTRUMENTATIONS FOR FOUR OUTGOING CIRCUITS IN ACCORDANCE WITH V.D.E SPECIFICATIAS INCLUDING SPARE PARTS.	22	

- 13- COMMITIONING OF ALL KNEW LIGHTING INSTALLATIONS 1 IN THE PRENENCE OF SITE ENGINEER AND PRESENTATION OF APPROVED CERTIFICATES IN THREE COPIES.
- 14- SUPPLY OF HIGH TENSION CABLES SIZE I-METER 3X150 mm² IN ACCOROLANCE WITH GENERAL SPESIFICATIONS.
- 15-SUPPLY OF LAW TENSION CABLES SIZE 3.5X240mm² I-METER.
- 16-SUPPLY OF LAW TENSION CABLES SIZE 3.5X240mm² I-METER.
- 17-SUPPLY OF HIGH TENSION CABLE TERMINAL 150mm² IN ACCORDANCE WITH GENERAL SPECIFICATIONS.
- 18- SUPPLY OF HIGH TENSION TRANSFORMERS 10.5KV ,1000KVA.
- 19- SUPPLY OF RING-MAIN UNITS 3-PHASE FEED HIGH TENSION 10.5 KV
- 20- SUPPLY OF LAW TENSION TRANSFORMERS 380V .1600amps.
- 21-SUPPLY OF DISTRIBUTION PANELS LOW-TENSION 380V.160amps.
- 22-INSTALLATION OF FUSE BOX LOW-TENSION DISTIZBUTION 380V. 160amps.
- 23- SUPPLY OF GALVANIZED STEEL PIPES AS REQUIRED FOR ITEM NO 22.